









Electrical Isolations

Ambrose Construct Group require the following when isolating electrical items on site
(i.e. light switches, GPOs etc.)

Item	Not Acceptable	Requirement
J-Box	 Exposed or taped wires	 All ends must be J-boxed
Light Switches	 Exposed light switches	 Must be J-boxed
Covered Back of Metal Brackets	 Metal bracket exposed	 Cover over metal bracket to prevent contact
Lock Out Tag Out of Electrical Switchboard	 Switchboard de-energised but no tag or lock to prevent re-energising	 Switchboard locked out and tagged out